


# BEFORE PROJECT CLEAR

## Incorrect Connections to the Public Sewer System



**A** The sump pump should **not** connect to the house lateral. It should drain onto the ground.

**B** Downspouts should **not** connect to the house lateral. They should drain onto the ground, into a rain barrel or into a raingarden.

**C** A missing clean-out cap allows stormwater into the public sewer system.

**D** Yard drains should **not** connect to the public sewer system. They should connect to the stormwater system instead.

DOWNSPOUT  
MISSING CLEAN-OUT CAP  
YARD DRAIN

SUMP PUMP  
HOUSE LATERAL

PUBLIC SEWER PIPE  
STORMWATER PIPE



# project clear

ProjectClearSTL.org

Project Clear STL projectclearstl